OPERATING SUMMARY

9

English to the second property

LIBRARY COPY

MAR 2 4 1975

MINISTRY OF THE ENVIRONMENT

WESTMINSTER TWP.

WATER POLLUTION CONTROL PLANT

3

Copyright Provisions and Restrictions on Copying:

This Ontario Ministry of the Environment work is protected by Crown copyright (unless otherwise indicated), which is held by the Queen's Printer for Ontario. It may be reproduced for non-commercial purposes if credit is given and Crown copyright is acknowledged.

It may not be reproduced, in all or in part, for any commercial purpose except under a licence from the Queen's Printer for Ontario.

For information on reproducing Government of Ontario works, please contact ServiceOntario Publications at copyright@ontario.ca



MINISTRY OF THE ENVIRONMENT

MINISTER Honourable William G. Newman

DEPUTY MINISTER E. Biggs

ASSISTANT DEPUTY MINISTER REGIONAL OPERATIONS J. Barr

REGIONAL OPERATIONS DIVISION

DIRECTOR, SOUTHWESTERN REGION D. McTavish

MANAGER, UTILITY OPERATIONS
A. Ladbrooke

WESTMINSTER TWP. WATER POLLUTION CONTROL PLANT

operated for

THE TOWNSHIP OF WESTMINSTER

by the


MINISTRY OF THE ENVIRONMENT

1973 ANNUAL OPERATING SUMMARY

prepared by
Plant Performance Unit
TECHNICAL SERVICES BRANCH
T. Cross, Director

CONTENTS

Title Page	•	•	•	•	•	•):	•	•	•	•	1
Flow Diagram	•	•	•	•	.	•	•	•	•		4
Design Data	•	٠	•	•	•	•	•	•	•	•	
Operating Cost	•	•	٠	•		•	•	•	•	•	(
Process Data					•		•		•		۶



DESIGN DATA

PROJECT Westminster Twp. WPCP

PROJECT NO.

2-0033-59

TREATMENT

Extended Aeration

DESIGN FLOW

0.25 mgd

DESIGN POPULATION 5,000

PRETREATMENT

Comminution

Type: Barminutor

Size: One Model B (12") Chicago Pump Co.

RAW SEWAGE PUMPS

Make: Chicago Pump
#1 - 100 gpm @ 23' tdh
Type: 4x4, 2hp electric
#2 - 100 gpm @ 23' tdh
Type: 4x4, 2hp electric
with standby Wisconsin

THD size $3\frac{1}{4} \times 3\frac{1}{4}$ gasoline engine

#3 - 250 gpm x 20' tdh Type: LMC4, 3 hp electric

SECONDARY TREATMENT

Aeration Tanks

Type: Diffused air; single-pass

Size: Two 54' x 27' x 14' (252,000 gal)

Retention: 24.2 hr

Diffusers

- Discfusers on swing arm

Air Supply

Type: Sutorbilt

Size: Three 337 scfm @ 7 psi

Secondary Sedimentation

Type: Link-Belt

Size: Two 54' x 8' x 9.25' (50, 200 gal)

Retention: 4.80 hr

Loading: Surface, 580 gal/ft²/day

Weir, 1955 gal/ft/day

CHLORINATION

Type: W & T

Size: One 100 lb/day

Chlorine Contact Chamber

Size: One 10' x 7' x 9' (3930 gal)

Retention: 22.7 min

OUTFALL

- to Dingman Creek

TERTIARY TREATMENT

Effluent Sand Filters

Size: Four units (26,900 sq ft or 0.62

acres)

Depth: 30" of sand (min)


Capacity: .405 mil gal/acre/day

SLUDGE HANDLING

Sludge Holding Tank

Size: 4,460 cu ft or 27,850 gal

ANNUAL COSTS



YEARLY OPERATING COSTS


YEAR	SEWAGE TREATED	TOTAL	UNIT COSTS				
	in million gallons	OPERATING COSTS	\$/M.G.	¢/lbBOD			
1968	76	\$ 15, 471	204	11			
1969	126	17, 264	137	16			
1970	146	24, 171	165	18			
1971	103	18,608	180	15			
1972	116	29,017	246	18			
1973	126	48, 788	388	25			


OPERATING EXPENDITURES

SALARIES AND WAGES	_	\$18, 183
EMPLOYEE BENEFITS	_	507
TRANSPORTATION & COMMUNICATIONS	_	1,023
SERVICES	_	11, 859
SUPPLIES AND EQUIPMENT	_	15, 106
ACQUISITION/CONSTRUCTION OF PHYSICAL ASSI	ets _	1.745
TRANSFER PAYMENTS	_	0
OTHER TRANSACTIONS		365
	TOTAL	\$48,788

PROCESS DATA

FLOWS







DESIGN CAPACITY _____

PLANT PERFORMANCE


	FLOWS			BIOCHEMICAL OXYGEN DEMAND				SUSPENDED SOLIDS				PHOSPHORUS		
	TOTAL FLOW	AVERAGE	MAXIMUM	INFLUENT	EFFLUENT	REDU	CTION	INFLUENT	EFFLUENT	RED	UCTION	INFLUENT	EFFLUENT	
момтн		DAY	DAY	/I	mg/l	%	10 ³ pounds	mg/l	mg/l	%	10 ³ pounds	mg/l P	mg/l P	
	million gallons	mil. gal	mgd	mg/l	mgzt	/0	podrids	mg/ t		/0	podiids	111471		
JAN	11.99	0.39	0.59	155	11	93	17	155	5	97	18	9.0	0.6	
FEB	9.58	0.34	0.66	135	10	93	12	140	8	94	13	8.2	0.6	
MAR	15.47	0.50	0.58	90	5	94	13	260	5	98	39	5.1	1.3	
APR	11.69	0.39	0.55	260	8	94	29	310	5	98	36	10.0	1.7	
MAY	11.10	0.36	0.51	130	3	98	14	233	7	97	25	7.9	1.2	
JUNE	10.47	0.34	0.49	310	4	99	32	225	5	98	23	6.1	1.1	
JULY	8.61	0.28	0.40	180	5	98	15	195	8	96	16	9.7	1.4	
AUG	4.29	0.14	0.27	190	2	99	8	260	12	95	11	7.9	0.7	
SEPT	7. 75	0.26	0.38	165	4	98	12	225	8	96	17	7.5	1.3	
ост	10.68	0.34	0.55	200	13	93	20	275	8	97	29	6.9	1.0	
NOV	12.92	0.43	0.58	120	11	91	14	200	20	90	23	5.9	0.9	
DEC	11.04	0.36	0.48	95	6	94	10	240	8	97	26	4.9	0.5	
TOTAL	125.59	-	-	-	-	-	192	_	_	-	276	÷	-	
AVG.		0.34	0.66	164	7	96	16	223	8	96	23	7.3	1.0	
No. of Sample	-	-	-	24	24	-	-	24	24	-		24	24	

BIOCHEMICAL OXYGEN DEMAND







PLANT INFLUENT -----




SUSPENDED SOLIDS



PHOSPHORUS





PLANT INFLUENT -----

TREATMENT DATA

	GRIT	CHLORIN	ATION	AE		WAST	TE SLUDGE		AEROBIC DIGESTER				
монтн	QUANTITY REMOVED	CI2 USED	AVG. DOSAGE	MLSS. CONC	F/M	AIR USED	QUANTITY 10 ³	SUSPENDED SOLIDS	VOL. SOLIDS	QUANTITY REMOVED	SUSPENDED SOLIDS	VOL. SOLIDS	AMOUNT HAULED
	cubic feet	pounds	mg/ι	mg/L	day-1	ID BOD	gallons	mg/l	%	10 ³ gallons	mg/l	%	cubic yards
JAN				3710	0.06	1.8	17	11660	69				
FEB				3150	0.06	2.3	6	8600	67				
MAR				2980	0.06	2.4	1	4850	63				
APR				3750	0.11	1.0	15	11550	68				
MAY		170	3.1	3830	0.05	2.1	11	10353	65				
JUNE		280	2.7	4150	0.10	0.9	25	12500	61				
JULY		304	3.6	3710	0.05		30	9230	61				
AUG		280	6.5	4370	0.02		5	7235	58				
SEPT		307	4.0	4250	0.06		21	7725	61				
ост.		345	3.2	4740	0.05		19	9700	66	38.4	5700	66	6.5
NOV		141*	2.5	3520	0.06		2	11150	66				
DEC				4340	0.03		3	14590	56				
TOTAL		1827	-	_	-		155	-	_	38.4	-	-	6.5
AVG.	cu. ft/mil gal		3.4	3880	0.06	1.8	13	9929	63		5700	66	

^{* 16} days chlorination



LABORATORY LIBRARY

